



NOTES:

1. DIRECTION OF TEE BRANCH TO BE DETERMINED BY THE LOCALITY.
2. TEE AND VALVE TO BE FLANGED.
3. TEE TO BE SAME SIZE AS EXISTING VALVE OR TAPPING VALVE.
4. MINIMUM SIZE VALVE TO BE USED IS 4" WITH NON-RISING STEM AND 2" SQUARE OPERATING NUT.

**FORCE MAIN CONNECTION
TO H.R.S.D. FORCE MAIN**

NOT TO SCALE

REFERENCE 200,803	CATEGORY SANITARY SYSTEMS	DATE 6/16	SHEET No. 1 OF 1	DETAIL No. SS_18
----------------------	------------------------------	--------------	---------------------	---------------------